

Log Of Daily Testing Of Water Gauges And Safety Controls.			Boiler Serial Number				
Date:	Mon	Tues	Wed	Thur	Fri	Sat	Sun
Water Gauge Cocks Tested							
Right Hand Glass							
Left Hand Glass							
Boiler TDS In PPM (Not Applicable)							
Boiler Blowdown (Bottom)							
Boiler Pressure Gauge Reading							
Water Level Control Test							
Water Feed Pump Operation							
Burner Stops Firing							
1st Low Water Alarm							
2nd Low Water Alarm							
Lockout Light Illuminated							
Burner Control Test							
UV Cell Removed While Burner Firing - Lockout							
Tested At (Time)							
Tested By.							
Log Examined By.							